

Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

The Principal
Army Public School
Udhampur

Dated: 22/04/2024


No: DFES-FP/9/2022-04(CC-7079422) 863

Sub: Provisional Fire Safety Certificate

Ref: Your online application submission dated 13.03.2024 (FI026-5829016)

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers in their school premises. The senior wing of the school is about 03 Km & junior wing of the school is 05 Km away from Fire and Emergency Station Udhampur and is approachable for fire appliances. Since the school is already functioning, as such, the management can proceed ahead for operation provisionally subject to adopt the following fire safety measures/ guidelines in letter and spirit forthwith -

1. A Down Comer of 4" dia should be provided in the Auditorium of the School building
2. 01 No. ABC Stored Pressure Type Fire Extinguisher of 04 Kg capacity each should be provided at strategic locations in all school buildings and 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
3. For all Double Storied Blocks, Hose Reel Hoses as per BIS specifications connected with the terrace water tank of 5000 Ltrs. capacity should be provided in the school building. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of each block are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel Hoses.
4. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
5. Fixed/First Aid Fire fighting system installed in the school building should be checked periodically. Staff and management should be fully trained in handling / operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
6. All electric installations existing in the building should be concealed conduit type.
7. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
8. The corridor of the building shall not be used for any kind of storage.
9. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
10. The management shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
11. At present school is having ten blocks in which six are double storey, three are single storey and one is four storied. In addition, two double storied family quarters block and one auditorium are also existing in the school premises. As such no addition / alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/ cancelled.
12. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this provisional clearance issued shall be treated automatically withdrawn/cancelled.
13. This provisional clearance shall be subject to outcome of any dispute/investigation/enquiry/trial if any pending before any Court of Law/investigation agency. This provisional clearance shall not confirm any title upon the person/company in whose favour it is issued.
14. The Provisional Fire Safety Certificate is issued in respect of the school with validity of six months for adoption of all Fire Safety Measures/ Guidelines mentioned above. The Final Fire Safety Certificate will be issued subject to fulfillment of all the Fire Safety Measures/ Guidelines in letter and spirit. However, before granting permission/ recognition/extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.


Director 22/04/2024
Fire & Emergency Services, J&K
Jammu/Srinagar